

Certified Validation Report: Provided by Validator

Audit Information:

Water Supplier Name: **City of San Jacinto** PWS ID: CA3310032

System Type: **Potable** Audit Period: **Financial 2019**

Utility Representation: Jason Wen and Michael Aguirre

Validation Date: **9/2/2020** Meeting Time: **2.00PM** Sufficient Supporting Documents Provided: **Yes**

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: **78** Data Validity Band (Level): **Band IV**

ILI: **0.13** Real Loss: **2.63 gallons/connections/day** Apparent Loss: **6.01 gallons/connection/day**

Non-revenue water as percent of cost of operating system: **0.8%**

Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

If not, rejected recommendations are included here.

Validator Information:

Water Audit Validator : **Tanmay Thakur** Qualifications: **Water Audit Validator Certificate issued by the CA-NV Section of the AWWA**

Validator Provided

Certified Validation Report Template, Part B: Provided by Utility

Water Supplier Name: CITY OF SAN JACINTO

Water Supplier ID Number: CA3310032

Water Audit Period: 1/1/2019-12/31/2019

Water Audit & Water Loss Improvement Steps:

Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

Keep tabs on all water used for outside services, record estimated water loss from leaks and flushing, respond as quickly as possible to repair leaking services and mains, calibrate all production meters, change out older and broken customer meters, review monthly production and water sold reports, check production from wells daily.

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (Print)

Executive Position

Signature

Date

MATHEW OSBORN

WATER SUPERVISOR



9/14/20

Utility Provided